



5 things to check for fire door safety



1. CERTIFICATION


Look for a label, a plug or similar marking to show that it's certificated & follow the instructions.

IMPORTANT: All ironmongery such as locks, latches, closers & hinges, MUST be CE marked & compatible with the door leaf's certification.



2. APERTURES

Altering the door for glazing apertures and air transfer grilles will make certification **VOID**.




3. GAPS & SEALS

Check the gap around the door frame is constant and around 3 to 4 mm & CE Marked hinges are firmly fixed with no missing screws. Ensure seals are fitted at the top and sides of the door.



4. CLOSERS

Check that the closer shuts the door onto the latch from any position – check from 75mm from the closed position.



5. OPERATION

Ensure the door closes correctly around all parts of the frame.